

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013875-R4
DATE: 10/16/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Boise Cascade
CODE: 1879-1
REVISION DATE: 04/21/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade, LLC 8260 Armstrong Road Milton, FL 32583	“Therma-Tru Smooth-Star/Fiber-Classic” Opaque Out-Swing Fiberglass Side-Hinged Door Configuration: X Frame: W-953mm(37.5") H-2054mm(80.88") Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG65 953 x 2054 (38 x 81)-LW SHD Design Pressure: 3120 Pa (65 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure : 440 Pa (9.20 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing, Inc.
Report No: B7234.01-501-47
Expiration Date: May 31, 2029

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com