

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013887-R3
DATE: 11/01/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "400" Vinyl Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1524mm(60") Panel: W-737mm(29") H-1464mm(57.62") STP: Pos+1190 Pa (25 psf) Neg-595 Pa (12.5 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1701.2-95/AAMA 1701.2-12 Federal Manufactured Home Construction & Safety Standard 3280.305 AAMA 1704-85/12	Manufactured Housing-Passed Wind Zone I Design Wind Pressure Rating: +25/-12.5 psf Egress-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-6252
Expiration Date: March 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023