

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013889-R2  
**DATE:** 11/01/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 10/20/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "400"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1829mm(72") Sash: W-1157mm(45.56") H-887mm(34.94") STP: Pos+1190 Pa (25 psf) Neg-595 Pa (12.5 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1701.2-95/AAMA 1701.2-12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b> <b>AAMA 1704-85/12</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone I</b> <b>Design Wind Pressure Rating:</b> <b>+25/-12.5 psf</b> <b>Egress-Passed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-6254  
Expiration Date: March 31, 2025

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)