# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI013889-R3** |
| **DATE:** | **11/01/2017** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **Ply Gem** |
| **CODE:** | **1408-1** |
| **REVISION DATE:** | **09/05/2024** |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Ply Gem Window Group**<br>**433 North Main Street**<br>**Rocky Mount, VA 24151** | **Series "400"**<br>**Vinyl Single Hung Window**<br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-1219mm(48") H-1829mm(72")<br>Sash: W-1157mm(45.56") H-887mm(34.94")<br>STP: Pos+1190 Pa (25 psf) Neg-595 Pa (12.5 psf) |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA 1701.2-95/AAMA 1701.2-12**<br>**Federal Manufactured Home Construction & Safety Standard 3280.305**<br>**AAMA 1704-85/12** | **Manufactured Housing-Passed**<br>**Wind Zone I**<br>**Design Wind Pressure Rating:**<br>**+25/-12.5 psf**<br>**Egress-Passed** |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-6254
Expiration Date: **March 31, 2027**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**