NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI013907.04-R4
DATE: 01/08/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 05/09/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "Aurora Custom" Opaque** **Fiberglass In-Swing French** **Double Door Assembly** Configuration: XX Frame: W-2487mm(97.91") H-3088mm(121.57") Panel: W-1213mm(47.76") H-3021mm(118.94")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-14 **ASTM E547-00(16)** **ASTM E1886-05/13a** **ASTM E1996-12a/14a**	**Design Pressure: 2400 Pa (50 psf)** **Positive Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 3120 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)** **Wind Zone 4 - Missile Level D**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17-096/W-1894/W-2022/W-2026
Expiration Date: **September 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com