NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013929.01-R4**
DATE:	**01/16/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Loewen**
CODE:	**1862-1**
REVISION DATE:	**10/16/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen **77 Highway 52 West** **Steinbach, Manitoba R5G 1B2**	**Series "StormForce"** **Eliptical Aluminum Clad Wood** **Transom** Configuration: O Glazing: IG-5/32" Tempered Glass/5/32" Annealed Glass/0.090 Kuraray SentryGlas Plus Interlayer/5/32" Annealed Glass Frame: W-2400mm(94.5") H-1219mm(48") DLO: W-2132mm(83.95") H-1065mm(41.95")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05** **ASTM E1886-02/05** **ASTM E1996-02/05** **TAS 201/202/203-94**	**Class CW-PG70 2400 x 1219 (94 x 48)-TR** **TR-C70 2400 x 1219 (94 x 48)** **Design Pressure: ±3360 Pa (70 psf)** **Positive Design Pressure: 3360 Pa (70 psf)** **Negative Design Pressure: 4800 Pa (100 psf)** **Water Penetration Resistance Test Pressure: 510 Pa (10.5 psf)** **Canadian Air Infiltration/Exfiltration Level: Fixed** **Wind Zone 4 - Missile Level D** **Large Missile Impact Rated**

Product Tested By: Architectural Testing Incorporated
Report No: 98270.01-201-44/98260.02-201-18/98260.01-201-18/W-1895/W-1921
Expiration Date: **January 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com