

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013953.01-R1
DATE: 02/06/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Rogue Valley
CODE: 671-1
REVISION DATE: 03/29/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Rogue Valley Door 123 Northeast Beacon Drive Grants Pass, OR 97526	Glazed Inswing Wood Side Hinged Double Door Assembly w/Transom Configuration: O/XX Glazing: IG-Ext-5/32" Tempered Glass/3/16" Annealed Glass/0.090" SentryGlas by Kuraray/ 3/16" Annealed Glass Frame: W-1886mm(74.25") H-3531mm(139") Panel: W-914mm(36") H-2419mm(95.25") DLO: W-635mm(25") H-2064mm(81.25") TR DLO: W-1695mm(66.75") H-762mm(30")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E331-00/E283-04 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: +60/-60 psf Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01741814/TEL 01701815/TEL 01741816
Expiration Date: March 31, 2026

A handwritten signature in black ink, appearing to be "SHE", is written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122