

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013953.06-R1  
**DATE:** 02/06/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Rogue Valley  
**CODE:** 671-1  
**REVISION DATE:** 03/29/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Rogue Valley Door</b><br><b>123 Northeast Beacon Drive</b><br><b>Grants Pass, OR 97526</b> | <b>Glazed Inswing Wood Radius Top</b><br><b>Side Hinged Door Assembly</b><br><b>(w/Latch &amp; Deadbolt Hardware)</b><br><br>Configuration: X<br>Glazing: IG-Ext-5/32" Tempered Glass/3/16"<br>Annealed Glass/0.090" SentryGlas by Kuraray/<br>3/16" Annealed Glass<br><br>Frame: W-1111mm(43.75") H-3092mm(121.75")<br>Panel: W-1065mm(41.94") H-3027mm(119.19")<br>DLO: W-784mm(30.88") H-1927mm(75.88") |

| SPECIFICATION   | PRODUCT RATING  |
|---|---|
| <b>ASTM E330-02/E331-00/E283-04</b><br><b>ASTM E1886-05/E1996-09</b><br><b>TAS 201/202/203-94</b> | <b>Design Pressure: +55/-75 psf</b><br><b>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</b><br><b>Wind Zone 4 - Missile Level D</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01741848/TEL 01701849  
Expiration Date: May 31, 2026

A handwritten signature in black ink, appearing to be "Shi".

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122