

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013990-R1
DATE: 03/19/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Harvey
CODE: 311-1
REVISION DATE: 02/22/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harvey Building Products, Inc. 7 Ledgewood Boulevard North Dartmouth, MA 02747	Series "8068" Vinyl Two-Lite Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2432mm(95.75") H-2025mm(79.75") Panel: W-1225mm(48.25") H-1959mm(77.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 2432 x 2025 (96 x 80)-SD Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Intertek
Report No: H7376.02-250-44
Expiration Date: **December 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com