

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014026-R1
DATE: 04/14/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Beijing Mylch
CODE: 2350-1
REVISION DATE: 01/04/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Beijing Mylch Building Products Co., Ltd 1388 Lin Xian Road Jinshan District, Shanghai 201505	Series "EX88S Tilt Turn" Thermally-Broken Aluminum w/Wood Cladding Dual Action Window Configuration: X Glazing: Triple Insulating Glass (Tempered) Frame: W-1200mm(47.25") H-1800mm(70.88") Sash: W-1037mm(40.82") H-1635mm(64.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-09	Class CW-PG80 1200 x 1800 (47 x 71)-DAW Design Pressure: ±3840 Pa (80 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek-Fresno
Report No: H9719.01-301-44
Expiration Date: January 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com