

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014027-R1  
DATE: 04/14/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Beijing Mylch  
CODE: 2350-1  
REVISION DATE: 01/04/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Beijing Mylch Building Products Co., Ltd</b> <b>1388 Lin Xian Road</b> <b>Jinshan District, Shanghai 201505</b>	<b>Series "EX88S Fixed"</b> <b>Thermally-Broken Aluminum</b> <b>w/Wood Cladding Dual Action Window</b>  Configuration: O Glazing: Triple Insulating Glass (Tempered)  Frame: W-1500mm(59.07") H-2000mm(78.75") DLO: W-1340mm(52.75") H-1842mm(72.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-09</b>	<b>Class CW-PG80 1500 x 2000 (59 x 79)-FW</b> <b>Design Pressure: ±3840 Pa (80 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek-Fresno  
Report No: H9722.01-301-44  
Expiration Date: January 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)