NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014115-R1**
DATE:	**06/11/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Guangzhou Alufront**
CODE:	**2413-1**
REVISION DATE:	**06/14/2022**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Guangzhou Alufront Aluminium Co., Ltd. **1F, C Building, No 12 Fucong Road** **Taiping Town, Conghua District,** **Guangzhou, Guangdong, China 510990**	**Series "ALU-ST1000"** **Aluminum Fixed Window** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.25") H-1499mm(59") DLO: W-1100mm(43.31") H-1397mm(55")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class R PG15 1200 x 1499 (47 x 59)-FW** **Design Pressure: ±718 Pa (15 psf)** **Positive Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 140 Pa (2.92 psf)**

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL 10216
Expiration Date: **May 31, 2032**

Administrator's Signature:_____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com