

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014131.01-R2  
**DATE:** 06/13/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Southeastern Door  
**CODE:** 684-1  
**REVISION DATE:** 06/22/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Southeastern Door Company</b> <b>1505 Commerce Lane</b> <b>Jupiter, FL 33458</b>	<b>Series "Atlas HP" Impact-Rated</b> <b>Aluminum Sliding Glass Door</b>  Configuration: OXXXXXP Glazing: Monolithic-1/4" Heat Strengthened Glass/ 0.090" Kuraray SGP Interlayer/1/4" Heat Strengthened Glass or 3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/ 0.090" Kuraray SGP Interlayer/1/8" Heat Strengthened Glass  Frame: W-7925mm(312") H-2616mm(102.5") Panel: W-1321mm(52") H-2551mm(100.44") DLO: W-1184mm(46.63") H-2389mm(94.06")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3112 Pa (±65 psf)</b> <b>Positive Design Pressure: 3112 Pa (65 psf)</b> <b>Negative Design Pressure: 3591 Pa (75 psf)</b> Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) <b>Large or Small Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-SED-16-001/W-2031  
Expiration Date: **September 30, 2024**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)