| CCBEDIN  | PRODUCT CERTIFICA   | TION —   |
|--|---|--|
| SU SUNAL ACCREDITED AND<br>SU SUNAL ACCREDITION<br>NAMENT INSTITUTED<br>R HANAGEMENT INSTITUTED<br>CERTIFIED PRODUCT | CERTIFICATION NO:<br>DATE:<br>CERTIFICATION PROGRAM:<br>COMPANY:<br>CODE:<br>REVISION DATE: | NI014131.01-R3<br>06/13/2018<br>Structural<br>Southeastern Door<br>684-1<br>03/05/2024 |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |  |
|---------------------------|--|--|
| Southeastern Door Company | Series "Atlas HP" Impact-Rated   |  |
| 1505 Commerce Lane        | Aluminum Sliding Glass Door  |  |
| Jupiter, FL 33458         | Configuration: OXXXXXP<br>Glazing: Monolithic-1/4" Heat Strengthened Glass/ 0.090" Kuraray<br>SGP Interlayer/1/4" Heat Strengthened Glass or 3/16" Heat<br>Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat<br>Strengthened Glass or IG-3/16" Tempered Glass/1/8" Heat<br>Strengthened Glass/ 0.090" Kuraray SGP Interlayer/1/8" Heat<br>Strengthened Glass |  |
|                           | Frame: W-7925mm(312") H-2616mm(102.5")   |  |
|                           | Panel: W-1321mm(52") H-2551mm(100.44")   |  |
|                           | DLO: W-1184mm(46.63") H-2389mm(94.06")   |  |

| SPECIFICATION                               | PRODUCT RATING  |
|---|---|
| TAS 201/202/203-94                          | Design Pressure: ±3112 Pa (±65 psf)<br>Positive Design Pressure: 3112 Pa (65 psf)<br>Negative Design Pressure: 3591 Pa (75 psf)<br>Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)<br>Large or Small Missile Impact Rated |
| Product Tested By: Blackwater Testing, Inc. |   |

Report No: Expiration Date: Blackwater Testing, Inc. BT-SED-16-001/W-2031 September 30, 2029

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>