

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014131.03-R2
DATE: 06/13/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Southeastern Door
CODE: 684-1
REVISION DATE: 06/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Southeastern Door Company 1505 Commerce Lane Jupiter, FL 33458	Series "Atlas HP" Impact-Rated Aluminum Sliding Glass Door Configuration: OXXXXXP Glazing: Monolithic-1/4" Heat Strengthened Glass/ 0.090" Kuraray SGP Interlayer/1/4" Heat Strengthened Glass or 3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/ 0.090" Kuraray SGP Interlayer/1/8" Heat Strengthened Glass Frame: W-7315mm(288") H-3061mm(120.5") Panel: W-1219mm(48") H-2996mm(117.94") DLO: W-41083mm(42.63") H-2834mm(111.56")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-SED-16-001/W-2031
Expiration Date: September 30, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com