

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014131.04-R3  
**DATE:** 06/13/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Southeastern Door  
**CODE:** 684-1  
**REVISION DATE:** 03/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Southeastern Door Company</b>  <b>1505 Commerce Lane</b>  <b>Jupiter, FL 33458</b>	<b>Series "Atlas HP" Impact-Rated</b>  <b>Aluminum Sliding Glass Door</b>  Configuration: OXXXXXP Glazing: Monolithic-1/4" Heat Strengthened Glass/0.035" Kuraray SGP Interlayer/1/4" Heat Strengthened Glass  Frame: W-7315mm(288") H-3061mm(120.5")  Panel: W-1219mm(48") H-2996mm(117.94")  DLO: W-41083mm(42.63") H-2834mm(111.56")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)</b> <b>Small Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-SED-16-001/W-2031  
Expiration Date: September 30, 2029

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023