

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014131.06-R3
DATE: 10/23/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Southeastern Door
CODE: 684-1
REVISION DATE: 03/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Southeastern Door Company 1505 Commerce Lane Jupiter, FL 33458	Series "Atlas HP" Impact-Rated Aluminum Sliding Glass Door Configuration: OXXXXX Glazing: Monolithic- 1/4" Heat Strengthened Glass/0.035" Kuraray SGP Interlayer/1/4" Heat Strengthened Glass Frame: W-7925mm(312") H-2616mm(102.5") Panel: W-1321mm(52") H-2551mm(100.44") DLO: W-1184mm(46.63") H-2389mm(94.06")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (±65 psf) Positive Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 3591 Pa (75 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) Small Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-SED-16-001/W-2031
Expiration Date: September 30, 2029

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023