

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014131.08-R2
DATE: 10/30/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Southeastern Door
CODE: 684-1
REVISION DATE: 06/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Southeastern Door Company 1505 Commerce Lane Jupiter, FL 33458	Series "Atlas HP" Aluminum Sliding Glass Door Configuration: OXXXXX Glazing: Monolithic (Tempered) Frame: W-7925mm(312") H-2616mm(102.5") Panel: W-1321mm(52") H-2551mm(100.44") DLO: W-1184mm(46.63") H-2389mm(94.06")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: ±2400 Pa (±50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3591 Pa (75 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)

Product Tested By: Blackwater Testing, Inc.
Report No: BT-SED-16-001/BT-SED-18-001
Expiration Date: September 30, 2024

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com