

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014137.07-R3  
DATE: 06/19/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: Nan Ya  
CODE: 661-1  
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation USA</b> <b>8989 North Loop East, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "SLPS" Glazed Fiberglass</b> <b>Outswing Side-Hinged Door Assembly</b> <b>w/Sidelites &amp; Sandwich Glazed</b>  Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Tempered Glass/Dupont Butacite PVB Interlayer/1/8" Tempered Glass  Frame: W-3720mm(146.44") H-2469mm(97.19") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-09</b> <b>ASTM E1886-05</b> <b>ASTM E1996-05/09</b>	<b>Class LC-PG50 3720 x 2469 (146 x 97)-SHD</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4103-07 (Revision 2)(Specimens 6 & 8)/NCTL-210-4103-08  
Expiration Date: **April 30, 2036**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)