

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014147-R1  
DATE: 07/11/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Air Master  
CODE: 2142-1  
REVISION DATE: 08/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Air Master Awning, LLC</b> <b>Road PR #2 interior KM 56.7</b> <b>Barceloneta, PR 00617</b>	<b>Series "Continental"</b> <b>Aluminum Projected Window</b>  Configuration: X Glazing: IG-1/4 Annealed Glass/3/16" Annealed Glass/0.090" Eastman Saflex Interlayer/3/16" Annealed Glass or Monolithic - 3/16" Annealed Glass/0.090" Eastman Saflex Interlayer/3/16" Annealed Glass  Frame:      W-914mm(36")      H-1829mm(72") Panel:      W-857mm(33.75")      H-1772mm(69.75") DLO:      W-730mm(28.75")      H-1619mm(63.75")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-14</b> <b>ASTM E1886-05/E1996-09</b> <b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3352 Pa (70 psf)</b> <b>Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf)</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Underwriters Laboratory, LLC  
Report No: SV31038-20180504  
Expiration Date: May 31, 2032

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)