

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014147.01-R1
DATE: 07/11/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Air Master
CODE: 2142-1
REVISION DATE: 08/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Air Master Awning, LLC Road PR #2 interior KM 56.7 Barceloneta, PR 00617	Series "Continental" Aluminum Casement Window Configuration: X Glazing: IG-1/4 Annealed Glass/3/16" Annealed Glass/0.090" Eastman Saflex Interlayer/3/16" Annealed Glass or Monolithic - 3/16" Annealed Glass/0.090" Eastman Saflex Interlayer/3/16" Annealed Glass Frame: W-914mm(36") H-1829mm(72") Panel: W-857mm(33.75") H-1772mm(69.75") DLO: W-730mm(28.75") H-1619mm(63.75")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ±3352 Pa (70 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Underwriters Laboratory, LLC
Report No: SV31038-20180521
Expiration Date: **May 31, 2032**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com