

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014150
DATE: 07/16/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Baja Storm Panel
CODE: 2456-1
REVISION DATE: 08/09/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Storm Panels S.A. DE C.V. Libramiento al Aeropuerto S/N, Edificio 1, Local 2, Col. Las Veredas Los Cabos, Baja California Sur, MX 23435 | Series "PH-POL25" Aluminum & Polycarbonate Impact Protection System Configuration: OOO Material: Aluminum/Polycarbonate Frame: W-3903mm(153.7") H-3110mm(122.4") Panel: W-1280mm(50.39") H-3075mm(121.1") |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| ASTM E330/E330M-14 ASTM E1886-13a ASTM E1996-14a | Design Pressure: ±2873 Pa (60 psf) Large Missile Impact Rated |

Product Tested By: Intertek
Report No: I3126.01-450-44
Expiration Date: April 30, 2027

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122