

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014156.01-R1  
**DATE:** 07/24/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Trimlite  
**CODE:** 2098-1  
**REVISION DATE:** 09/19/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Trimlite, LLC</b> <b>901 SW 39<sup>th</sup> Street</b> <b>Renton, WA 98057</b>	<b>Series "Solution" Non-Impact</b> <b>Vinyl Door Lite Frame Assembly</b> <small>(Tested w/Plastpro Fiberglass Outswing Side-Hinged Door Assembly)</small>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame:      W-953mm(37.5")    H-2489mm(98") Panel:      W-914mm(36")      H-2419mm(95.25") Lite Frame: W-603mm(23.75") H-432mm(17") DLO:        W-533mm(21")      H-362mm(14.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04/E331-00/E330-02</b>	<b>Design Pressure: ±2633 Pa (55 psf)</b> Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 06902065  
Expiration Date: June 30, 2025

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)