

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014156.03-R2
DATE: 07/24/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Trimlite
CODE: 2098-1
REVISION DATE: 09/19/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Trimlite, LLC 901 SW 39th Street Renton, WA 98057	Plastpro Fiberglass Outswing Side-Hinged Door w/Trimlite "Solution" Vinyl Door Lite Frame Assembly Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.5") H-2489mm(98") Panel: W-914mm(36") H-2419mm(95.25") Lite Frame: W-603mm(23.75") H-432mm(17") DLO: W-533mm(21") H-362mm(14.25")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E331-00/E330-02	Design Pressure: ±2633 Pa (55 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 06902065
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com