

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014160-R1
DATE: 07/25/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Survivalite
CODE: 1872-1
REVISION DATE: 02/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Survivalite Impact Window Systems, LLC 1385 Morningside Drive Mount Dora, FL 32757	Series "Survivalite Fixed" Aluminum Fixed Window (Tornado Only) Configuration: O Glazing: IG-1/4" Polycarbonate/0.025" Clear Film Interlayer/1/4" Polycarbonate/0.025" Clear Film Interlayer/1/8" Polycarbonate/0.025" Clear Film Interlayer/1/8" Polycarbonate/1/4" Annealed Glass Frame: W-1524mm(60") H-2438mm(96") DLO: W-1346mm(53") H-2261mm(89")

SPECIFICATION	PRODUCT RATING
FEMA 361-08 (Section 6) ICC 500-08/14 (Sections 804 & 806.4.1) ASTM E330-02	Passed Design Pressure: +250/-250 psf

Product Tested By: Blackwater Testing, Inc.
Report No: BT-SIS-17-001
Expiration Date: August 31, 2024

Administrator's Signature:  _____

NATIONAL ACCREDITATION & MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023