

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014160.02-R1  
**DATE:** 07/25/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Survivalite  
**CODE:** 1872-1  
**REVISION DATE:** 02/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Survivalite Impact Window Systems, LLC</b> <b>1385 Morningside Drive</b> <b>Mount Dora, FL 32757</b>	<b>Series "Survivalite Fixed"</b> <b>Aluminum Fixed Window</b>  (Hurricane Only)  Configuration: O Glazing: IG-1/4" Polycarbonate/0.025" Clear Film Interlayer/1/4" Polycarbonate/0.025" Clear Film Interlayer/1/8" Polycarbonate/0.025" Clear Film Interlayer/1/8" Polycarbonate/1/4" Annealed Glass  Frame: W-1524mm(60") H-2438mm(96") DLO: W-1346mm(53") H-2261mm(89")

SPECIFICATION	PRODUCT RATING
<b>FEMA 361-08 (Section 6)</b> <b>ICC 500-08/14</b> <b>(Sections 804 &amp; 806.4.2)</b> <b>ASTM E330-02</b>	<b>Passed</b> <b>Design Pressure: +110/-130 psf</b>

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-SIS-17-001  
Expiration Date: August 31, 2024

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023