

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014161-R2
DATE: 07/27/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Tapco
CODE: 1247-1
REVISION DATE: 05/30/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
TAPCO, Inc. 1815 McCullough Boulevard Tupelo, MS 38801	Series "950" Patio Screen Enclosure w/Fin Configuration: O/O Mill Finish Aluminum Frame: W-3200mm(126") H-3086mm(121.5")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E1886-05/E1996-05/09 TAS 201/202/203-94	Design Pressure: +70/-70 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories.
Report No: NCTL-210-4096-01/NCTL-210-4096-01A
Expiration Date: **February 28, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com