

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014169-R1
DATE: 08/09/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Eurocraft
CODE: 2409-1
REVISION DATE: 04/25/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eurocraft Industries, Inc. 7905 Northwest 77th Avenue Medley, FL 33166	Series "76 MD" Vinyl Double Tilt & Turn Window Configuration: X/X Glazing: IG- 1/4" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Kuraray Sentry Glass Interlayer/3/16" Heat Strengthened Glass Frame: W-2602mm(102.44") H-1613mm(63.5") Sash: W-1251mm(49.25") H-1524mm(60") DLO: W-1094mm(43.06") H-1369mm(53.9")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 575 Pa (12.0 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4116-07
Expiration Date: **December 31, 2024**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com