

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014188-R2
DATE: 08/23/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Eurocraft
CODE: 2409-1
REVISION DATE: 04/25/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eurocraft Industries, Inc. 7905 Northwest 77th Avenue Medley, FL 33166	Series "76 MD Vinyl In-Swing Balcony Door" Vinyl Balcony Door Configuration: X Glazing: IG- 1/4" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Kuraray SentryGlas Interlayer/3/16" Heat Strengthened Glass Frame: W-1168mm(46") H-2108mm(83") Panel: W-1073mm(42.25") H-2026mm(79.75") DLO: W-914mm(36") H-1867mm(73.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05/09 TAS 201/202/203-94	Class LC-PG65 1168 x 2108 (46 x 83)-DASHD Design Pressure: ±3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4116-10/NCTL-210-4116-09
Expiration Date: December 31, 2024

A handwritten signature in black ink, appearing to be "Shi".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com