

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014237-R1
DATE: 10/16/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Trimlite
CODE: 2098-1
REVISION DATE: 09/19/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Trimlite, LLC 901 SW 39th Street Renton, WA 98057	Series "Impact Lite Frame Assembly" Aluminum Door Lite Frame Assembly (Tested w/Various Steel Fixed Side-Hinged Door Assemblies) Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-953mm(37.5") H-2057mm(81") Panel: W-914mm(36") H-2013mm(79.25") Lite Frame: W-610mm(24") H-1673mm(65.88") DLO: W-533mm(21") H-1597mm(62.88")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E331-00/E330-02 ASTM E1886-05 ASTM E1996-09	Design Pressure: ±2873 Pa (60 psf) Positive Design Pressure: 2873 Pa (60 psf) Negative Design Pressure: 3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 06901967
Expiration Date: **January 31, 2025**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com