

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI014237.01-R1
DATE:	10/16/2018
CERTIFICATION PROGRAM:	Structural
COMPANY:	Trimlite
CODE:	2098-1
REVISION DATE:	09/19/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Trimlite, LLC 901 SW 39th Street Renton, WA 98057</p>	<p style="text-align: center;">Series "Impact Lite Frame Assembly"</p> <p style="text-align: center;">Aluminum Door Lite Frame Assembly</p> <p style="text-align: center;">(Tested w/Various Steel Fixed Side-Hinged Door Assemblies)</p> <p style="text-align: center;">Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/.090" Saflex PVB Interlayer/1/8" Annealed Glass</p> <p>Frame: W-953mm(37.5") H-2464mm(97")</p> <p>Panel: W-914mm(36") H-2419mm(95.25")</p> <p>Lite Frame: W-610mm(24") H-2083mm(82")</p> <p>DLO: W-529mm(20.81") H-2007mm(79")</p>

SPECIFICATION	PRODUCT RATING
<p>ASTM E283-04/E331-00/E330-02 ASTM E1886-05 ASTM E1996-09</p>	<p>Design Pressure: ±2873 Pa (60 psf) Positive Design Pressure: 2873 Pa (60 psf) Negative Design Pressure: 3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) Wind Zone 4 - Missile Level D</p>

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: TEL 06901967
 Expiration Date: **January 31, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com