NOTICE OF PRODUCT CERT	IFICATION
CERTIFICATION PROGR COMPA	NO: <u>NI014256-R1</u> ATE: <u>11/06/2018</u> AM: <u>Structural</u> ANY: <u>Beijing Mylch</u> DDE: <u>2350-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
Beijing Mylch Building Products Co., Ltd	Series "DR65"		
1388 Lin Xian Road	Thermally-Broken Aluminum		
Jinshan District, Shanghai 201505	In-Swing Side Hinged Door		
		Configuratio	
		Glazing: Insulating Gla	ss (Tempered)
	Frame:	W-1100mm(43.31")	H-2600mm(102.36")
	Panel:	W-1006mm(39.61")	H-2506mm(98.66")
	DLO:	W-827mm(32.56")	H-2327mm(91.61")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class CW-PG60 1100 x 2600 (43 x 102)-SHD Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Report No: Expiration Date: Intertek Testing Service Shenzhen Ltd. 180831010SHF-002 October 31, 2026

Sh

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023