NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014264.01-R2**
DATE:	**11/15/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**ViWinTech**
CODE:	**583-1**
REVISION DATE:	**07/08/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors **2400 Irvin Cobb Drive** **Paducah, KY 42003**	**Series "Shoreline"** **Out-Swing Vinyl Casement Window** **New Construction /Equal Leg/Flange Frame** Configuration: X Glazing: Insulating Glass-Laminate Glass-1/8" Annealed Glass/0.090" PVB Kuraray®/1/8" Annealed Glass Frame: W-914mm(36") H-1829mm(72") Vemt: W-851mm(33.5") H-1769mm(69.62") DLO: W-768mm(30.25") H-1686mm(66.38")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 **ASTM E1886-13a/E1996-14a** **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Design Pressure: ±2400 Pa (50 psf)** **Wind Zone 3-Missile Level D** **Class LC-PG60 914 x 1829 (36 x 72)-C** **Water Penetration Resistance Test Pressure: 440 Pa (9.18 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Intertek
Report No: I8770.02-501-47
Expiration Date: **September 30, 2031**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com