

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014277-R3
DATE: 12/05/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Dunbarton
CODE: 1319-1
REVISION DATE: 12/23/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dunbarton Corporation 555 Benton Industrial Road Camden, TN 38320	“Rediflex Steel Frame w/Opaque Inswing Steel Door Configuration: X Frame: W-997mm(39.25") H-2099mm(82.63") Panel: W-909mm(35.75") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/12 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sections)	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01092228/W-2144
Expiration Date: November 30, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com