

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014294-R1  
**DATE:** 01/07/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Pacific Crest  
**CODE:** 2516-1  
**REVISION DATE:** 08/28/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Pacific Crest Building Products</b> 4227 South Meridian, C-114 Puyallup, WA 98373	<b>Series "3-Lite"</b> <b>Glazed Wood Inswing Side-Hinged Door</b>  Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-945mm(37.19") H-2070mm(81.5") Panel: W-914mm(36") H-2005mm(78.94") DLO: W-201mm(7.94") H-409mm(16.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG45 945 x 2070 (37 x 81)-LWSHDX</b> <b>Design Pressure: ±2160 Pa (45 psf)</b> Water Penetration Resistance Test Pressure: 0 Pa (0 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: I9562.01-301-44  
Expiration Date: October 31, 2025

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)