NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014318.02-R2**
DATE:	**01/17/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Hoelscher**
CODE:	**1765-1**
REVISION DATE:	**10/07/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hoelscher Weatherstrip Manufacturing Company, Inc. **2400 S. Persimmon Street** **Tomball, TX 77375**	**"3068 Mahogany 6 Panel"** **Opaque Wood In Swing Side-Hinged Door** Configuration: X Frame: W-957mm(37.69") H-2027mm(79.81") Panel: W-914mm(36") H-1984mm(78.25")

SPECIFICATION	PRODUCT RATING
ASTM E330-14	**Design Pressure: ±2400 Pa (50 psf)**

Product Tested By: Intertek, PLC
Report No: J0896.02-801-44
Expiration Date: **December 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com