

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014354-R1
DATE: 02/20/2019
CERTIFICATION PROGRAM: Structural
COMPANY: SL Westwood
CODE: 2301-1
REVISION DATE: 11/28/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Front Row Hurricane Shutters Buena Vista s/n, Local S Colonia Nucleo Agrairo Cabo San Lucas, B.C.S., Mexico 23472	“Polypropylene Hurricane Storm Panels” Non-Porous Polypropylene Hurricane Storm Panel 14 Foot System - H3 w/Aluminum Frame Configuration: OOO Frame: W-3137mm(123.5") H-4248mm(167.25") Panel: W-991mm(39") H-4248mm(167.25")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-05 ASTM E1996-09	Design Pressure: 2873 Pa (60 psf) Positive Design Pressure: 2873 Pa (60 psf) Negative Design Pressure: 3352 Pa (70 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 07552030
Expiration Date: April 30, 2025

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com