NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014369-R4**
DATE:	**03/21/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**05/14/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "Pro Classic/1500/5700"** **Vinyl Fixed Sidelite/Transom Window** Configuration: O Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Eastman Saflex Interlayer/1/8" Annealed Glass Frame: W-968mm(38.13") H-2072mm(81.56") Sash: W-902mm(35.5") H-2002mm(78.81") DLO: W-781mm(30.75") H-1876mm(73.88")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 **ASTM E1886-02/04/05/09/13a** **ASTM E1996-02/04/06/09/12a/14a** **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class LC-PG50 968 x 2072* (38 x 82*)-SLT** **Design Pressure: ±2400 Pa (50 psf)** **Positive Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2873 Pa (60 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf)** **Wind Zone 3 - Missile Level D**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 110-21907-1/NCTL 110-21569-1/NCTL 110-21568-1
Expiration Date: **October 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com