

NOTICE OF PRODUCT CERTIFICATION



Company: BMC Millwork
105 Broughton Street
Ailey, GA 30410

Certification No.: NI014387.02-R1
Certification Date: 04/16/2019
Expiration Date: 04/30/2026
Revision Date: 07/20/2023

Product: Fiberglass Glazed Inswing or Outswing Door w/ and w/o Non-Impact Rated Sidelites
3/4 Lite of Less Doors w/ and w/o Full-Lite or Less Sidelites (w/Wood Frame or Worldwide
Composite Frame⁴ unless noted)

Specification: TAS 202-94/ASTM E330-02 **Glazing:** Insulating Glass (Tempered)

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed 3/4-Lite Max	3'0" x 6'8"	+50/-50	0.0 psf	No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
X Single	O/S	Glazed 3/4-Lite Max	3'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /9.0 psf ⁵ 7.5 psf ⁶	No	ATLNC 1012.01-16R/W-1813/W-1843/W-1860 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XX Double	I/S	Glazed 3/4-Lite Max	6'0" x 6'8"	+50/-50	0 psf	No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XX Double	O/S	Glazed 3/4-Lite Max	6'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /8.25 psf ⁵	No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XO/OX Single w/Sidelite	I/S	Glazed 3/4-Lite Max Full-Lite Max S/L	6'0" x 6'8"	+50/-50	0 psf	Door-No Sidelite-No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XO/OX Single w/Sidelite	O/S	Glazed 3/4-Lite Max Full-Lite Max S/L	6'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /9.0 psf ⁵	Door-No Sidelite-No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXO Single w/Sidelites	I/S	Glazed 3/4-Lite Max Full-Lite Max S/L	9'0" x 6'8"	+50/-50	0 psf	Door-No Sidelites-No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXO Single w/Sidelites	O/S	Glazed 3/4-Lite Max Full-Lite Max S/L	9'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /9.0 psf ⁵	Door-No Sidelites-No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXXO Double w/Sidelites	I/S	Glazed 3/4-Lite Max Full-Lite Max S/L	12'4" x 6'8"	+50/-50	0 psf	Door-No Sidelites-No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXXO Double w/Sidelites	O/S	Glazed 3/4-Lite Max Full-Lite Max S/L	12'4" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /8.25 psf ⁵	Door-No Sidelites-No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17

1 -Denotes Bumper Outswing Threshold 2 -Denotes Z-Series Outswing Threshold 3-Hi-Dam Outswing Threshold 4-W-1815 5-Worldwide Pro T4 Threshold 6-Denotes HP Outswing Threshold

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'S.M.D.', is written over a horizontal line that serves as the signature line.