

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014427-R1
DATE: 05/27/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Crest Doors
CODE: 1125-1
REVISION DATE: 06/27/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namincertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Steve's and Sons, Inc. 211 New Laredo Highway San Antonio, TX 78211 | Series "Opaque" Steel Inswing Door Configuration: X Frame: W-953mm(37.5") H-2070mm(81.5") Panel: W-908mm(35.75") H-2007mm(79") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.305 | Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf |

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01522273
Expiration Date: April 30, 2025

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com