

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014496.05-R3
DATE: 01/18/2020
CERTIFICATION PROGRAM: Structural
COMPANY: COMEP Infissi
CODE: 2240-1
REVISION DATE: 03/25/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Co.Me.P Infissi SRL Viale Europa, 440 51039 Santonuovo PT	Series "EBE" Inside or Outside Glazed Brass or Steel Fixed Window (Rectangle or Arch Top) Configuration: O Glazing: IG-1/4" Tempered Glass/1/4" Heat Strengthened Glass/0.090" DuPont SGP Interlayer/1/4" Heat Strengthened Glass Frame: W-1524mm(60") H-3658mm(144") DLO: W-1461mm(57.5") H-3594mm(141.5")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2633 Pa (55 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-CMP-17-001/W-1910
Expiration Date: August 31, 2032

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com