

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014496.06-R2  
DATE: 01/18/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: COMEP Infissi  
CODE: 2240-1  
REVISION DATE: 03/25/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Co.Me.P Infissi SRL</b> <b>Viale Europa, 440</b> <b>51039 Santonuovo PT</b>	<b>Series "EBE"</b> <b>Brass or Steel Fixed Window</b> <b>(Inside or Outside Glazed)</b>  Configuration: O Glazing: IG-1/4" Tempered Glass/1/4" Heat Strengthened Glass/0.090" DuPont SGP Interlayer/1/4" Heat Strengthened Glass  Frame: W-1067mm(42") H-3048mm(120") DLO: W-1003mm(39.5") H-2985mm(117.5")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3591 Pa (75 psf)</b> Water Penetration Resistance Test Pressure: 539 Pa (11.25 psf) <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-CMP-17-001/W-1910  
Expiration Date: August 31, 2032

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)