

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014503.01-R2
DATE: 09/18/2019
CERTIFICATION PROGRAM: Structural
COMPANY: ASSA ABLOY
CODE: 668-1
REVISION DATE: 03/13/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>ASSA ABLOY Entrance Systems US, Inc.</p> <p>1900 Airport Road</p> <p>Monroe, NC 28110</p>	<p>“Full Breakout Single Slide Door System”</p> <p>Impact Rated Single Slide Door System</p> <p style="text-align: center;">(Panic Exit Device)</p> <p style="text-align: center;">Configuration: SO/SX Glazing: Monolithic-Laminate- 1/4" Heat Strengthened Glass/0.090" SentryGlas by Kuraray/1/4" Heat Strengthened Glass or IG-3/16" Tempered Glass/Laminate-3/16" Tempered Glass/0.090" SentryGlas by Kuraray/ 3/16 Heat Strengthened Glass</p> <p>Frame: W-2743mm(108") H-2642mm(104")</p> <p>Panel: W-1384mm(54.5") H-2438mm(96")</p> <p>DLO: W-1191mm(46.88") H-2083mm(82")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/202*/203-94</p> <p>ASTM F842</p>	<p>Design Pressure: +80/-80 psf</p> <p>Large Missile Impact Rated</p> <p>Forced Entry Resistance: Passed/Grade 25</p>

*No Water Penetration Test Performed

Product Tested By: Intertek-Georgia
 Report No: J5787.02-550-18/J5787.01-550-18
 Expiration Date: **June 30, 2029**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/Email: nami@namiinc.com