

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014504.02-R2
DATE: 09/18/2019
CERTIFICATION PROGRAM: Structural
COMPANY: ASSA ABLOY
CODE: 668-1
REVISION DATE: 03/12/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ASSA ABLOY Entrance Systems US, Inc. 1900 Airport Road Monroe, NC 28110	“Full Breakout Single Slide Door System” Non-Impact Single Slide Door System (3 Point Locking System) Configuration: SO/SX Glazing: Monolithic-1/4" Tempered Glass Frame: W-2743mm(108") H-2642mm(104") Panel: W-1368mm(53.88") H-2374mm(93.5") DLO: W-1181mm(46.5") H-2085mm(82.12")

SPECIFICATION	PRODUCT RATING
TAS 202*-94 ASTM F842	Design Pressure: +85/-85 psf Forced Entry Resistance: Passed/Grade 25

*No Water Penetration Test Performed

Product Tested By: Intertek-Georgia
Report No: J5785.11-550-18/J5787.09-550-18
Expiration Date: **June 30, 2029**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023