NOTICE OF PRODUCT CERTIFICATION

ATOPS ACCREDITED ARO	CERTIFICATION NO:	NI014505-R1
	DATE:	09/20/2019
(CPU / H	CERTIFICATION PROGRAM:	Structural
TANAGE STIL	COMPANY:	ASSA ABLOY
CEATING DOODUCT	CODE:	668-1
WED PRO	REVISION DATE:	03/12/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ASSA ABLOY Entrance Systems US, Inc.	"Full Breakout Bi-Part Door System"
1900 Airport Road	Impact Rated Bi-Part Door System
Monroe, NC 28110	
	Configuration: SO/SX/SX/SO Glazing: Monolithic-Laminate- 1/4" Heat Strengthened Glass/0.090" SentryGlas by Kuraray/1/4" Heat Strengthened Glass or IG-3/16" Tempered Glass/Laminate-3/16" Tempered Glass/0.090" SentryGlas by Kurary/ 3/16" Heat Strengthened Glass or Laminate-1/4" Heat Strengthened Glass/0.180" SentryGlas by Kurary/1/4" Heat Strengthened Glass Frame: W-4877mm(192") H-2642mm(104") Panel: W-1229mm(48.5") H-2438mm(96")
	DLO: W-1061mm(41.75") H-2095mm(82.5")

SPECIFICATION	PRODUCT RATING
TAS 201/202*/203-94 ASTM F842	Design Pressure: +80/-80 psf Large Missile Impact Rated Forced Entry Resistance: Passed/Grade 25

Expiration Date:	June 30, 2029
Report No:	J5787.06-550-18
Product Tested By:	Intertek-Georgia
*No Water Penetration Tes	t Performed

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124/Email: <u>nami@namiinc.com</u>

NOPC-03/30/2023