

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014505.02-R1
DATE: 09/20/2019
CERTIFICATION PROGRAM: Structural
COMPANY: ASSA ABLOY
CODE: 668-1
REVISION DATE: 03/12/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ASSA ABLOY Entrance Systems US, Inc. 1900 Airport Road Monroe, NC 28110	“Full Breakout Bi-Part Door System” Impact Rated Bi-Part Door System Configuration: SO/SX/SX/SO Glazing: Monolithic-Laminate- 1/4" Heat Strengthened Glass/0.180" SentryGlas by Kuraray/1/4" Heat Strengthened Glass Frame: W-4877mm(192") H-2642mm(104") Panel: W-1222mm(48.12") H-2438mm(96") DLO: W-1061mm(41.75") H-2083mm(82")

SPECIFICATION	PRODUCT RATING
TAS 201/202*/203-94 ASTM F842	Design Pressure: +80/-80 psf Large Missile Impact Rated Forced Entry Resistance: Passed/Grade 25

*No Water Penetration Test Performed

Product Tested By: Intertek-Georgia
Report No: J5787.08-550-18/J5787.06-550-18
Expiration Date: **June 30, 2029**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023