NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI014529.01-R1
DATE: 10/12/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2288-1
REVISION DATE: 05/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems **3400 Tacoma Street** **Union Gap, WA 98903**	**Series "1000"** **Vinyl Fixed Next to Tilt Turn Window** **FW-DAW** Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-1816mm(71.5") Sash: W-1060mm(41.75") H-1740mm(68.5") Max DLO: W-889mm(35") H-1575mm(62")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class CW-PG35 1816 x 1816 (72 x 72)-FW-DAW** **Design Pressure: ±1680 Pa (±35 psf)** **Canadian Air Infiltration/Exfiltration Level: A2** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Intertek-Kent, WA
Report No: J6050.01-901-44/G0275.01-901-44/J6052.01-901-44
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com