NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014531-R1**
DATE:	**10/14/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Quaker**
CODE:	**031-1**
REVISION DATE:	**03/12/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "V100"** **Vinyl Single Hung** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-954mm(37.56") H-784mm(30.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class R-PG40 1016 x 1600 (40 x 63)-H** **Design Pressure: ±1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)**

Product Tested By: Intertek-Plano, TX
Report No: J8188.01-801-47-R1
Expiration Date: **June 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com