

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014545-R1
DATE: 10/28/2019
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1
REVISION DATE: 04/12/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors 2400 Irvin Cobb Drive Paducah, KY 42003	Series "SL 2100" Vinyl Single Hung Window Configuration: O/X Glazing: Insulated Glass (Annealed) Frame: W-1118mm(44") H-1905mm(75") Vent: W-1038mm(44.08") H-929mm(36.56") DLO: W-1000mm(39.38") H-889mm(35")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ANSI/AAMA/WDMA 101/I.S.2/NAFS-02 ANSI/AAMA/WDMA 101/I.S.2-97	Class LC-PG35 1118 x 1905 (44 x 75)-H H-LC35 1118 x 1905 (44 x 75) H-LC35 44 x 75 Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.25 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Quast Consulting and Testing, Inc.
Report No: QCT11-2267.01a
Expiration Date: September 30, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com