

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014553.03-R1  
**DATE:** 11/19/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Plyco  
**CODE:** 765-1  
**REVISION DATE:** 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Plyco Corporation</b> <b>dba Modern Door Corporation</b> <b>500 Industrial Road/PO Box 386</b> <b>Elkhart Lake, WI 53020</b>	<b>"4070 Series 20 EV"</b> <b>Full-Lite Out-Swing Steel</b> <b>Side-Hinged Door</b> w/ & w/o Single Lock and Deadbolt Engaged Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1318mm(51.88") H-2169mm(85.38") Panel: W-1213mm(47.75") H-2112mm(83.13") DLO: W-559mm(22") H-1524mm(60")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b> <b>ASTM E331-00(2016)</b>	<b>Design Pressure: 1440 Pa (30 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</b>

Product Tested By: Element Materials Technology, Inc.  
Report No: ESP031518P-2458.6  
Expiration Date: August 31, 2026

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)